

**Test Report**

Report Number: 160621007SHF-BP-3R2

**Applicant Name:** Stone Barn Floors **Report Date:** July 11, 2016  
**Revised Data:** July 27, 2016

**Applicant Address:** 750 East Covey Lane, Suite 100  
Phoenix, Arizona 85024

**Attn:** Bob Boulden

**Sample Description:**

**Manufacturer Name:** Taizhou Huali Plastic co., Ltd  
**Product:** LVT Click 3.2mm  
**Model:** CLSMBS-48-72-32-12-S  
**Sample Quantity:** 74 pieces  
**Sample ID:** S160621007SHF-073~146  
**Date Received:** 2016/6/21  
**Date Test Conducted:** 2016/6/21~2016/7/11

**Tests Conducted:**

As requested by the applicant, for details refer to attached pages(s).

**Conclusion:**

For details refer to attached page(s). Supersede or Amendment to Report No. 160621007SHF-BP-3R1 ( Add Manufacturer Name)

The conclusions of this test report may not be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.

**Test Items, Method and Results:**

Test method: ASTM E90-09


Temperature: 27 °C                      Relative Humidity: 70 %

Volume of the source room: 84 m<sup>2</sup>                      Volume of the receiving room 121 m<sup>2</sup>

Specimen area: 12.8 m<sup>2</sup> (detail drawing see Test Photos)

Floor assembly: The system consisted of 150mm thick concrete floor and the 3.4mm LVT Click were placed on the concrete floor.

Frequency (Hz)	TL (dB)
100	40.6
125	34.7
160	38.1
200	38.6
250	38.8
315	40.6
400	44.5
500	45.8
630	47.9
800	49.5
1000	52.0
1250	54.3
1600	56.5
2000	59.2
2500	61.0
3150	62.3
4000	64.1
5000	65.7



**Calculated Sound Transmission Class: STC 50**

Note:

1. TL= Transmission loss
2. Classified STC in accordance with ASTM E413-10, Classification for Rating Sound Insulation.
3. The STC was for the whole floor assembly system.

**Test Photo:**



Test set up

**Appendix A: Sample received photo**



**Approved by:**

*Dorian Wu*

Name: Dorian Wu  
Title: Approver

*Jodie Zhou*

Name: Jodie Zhou  
Title: Reviewer

*Evyn Cui*

Name: Evyn Cui  
Title: Project Engineer

\*\*\*\*\*

The End of Report

*This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*