

Test Report

Report Number:141013003SHJ-BP-1

Applicant Name: Taizhou Huali Plastic Co., Ltd
Applicant Address: Zhangdian Industrial Zone, Jiangyan,
Jiangsu Prov., P.R.China
Attn: Henry Xu

Original Report Date: November 3, 2014**Sample Description:**

Product: Click Vinyl Flooring
Model: Art. No.: 22502388 and 22900858
Samples Quantity: 4 pieces
Sample ID: S141013003SHJ-001~004
Date Received: 2014-10-11
Date Test Conducted: 2014-10-13~2014-11-03

Tests Conducted:

Test Methods: EN 12667:2001


Conclusion:

For details refer to attached page(s).
The conclusions of this test report may not be used as part of the requirements for Intertek product certification.
Authority to Mark must be issued for a product to become certified.


Should you have any queries about the test report, please contact:

Approved by: **Checked by:** **Prepared by:**

Sun Sun
Assistant Manager



Sally Xie
Technical supervisor



Eryn Cui
Assistant Engineer

Test Items, Method and Results:

Test item	Test method	Test condition	Test result (W/m·K)
Thermal conductivity	EN 12667:2001	Mean temperature: 25°C Temperature difference: 20°C	0.21674

Note:

1. Test was conducted at the external approved/qualified facility, located at [Foshan].

ORIGINAL

Appendix A: Sample photos



Sample received

The End of Report

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.