

**Test Report****Report Number: 160107002SHF-BP-1****Applicant Name: Taizhou Huali Plastic Co. Ltd. Report Date: January 18, 2016****Applicant Address: Zhangdian Industrial Zone,  
Jiangyan, Jiangsu Prov., P. R.  
China****Attn: Philip Yuan****Sample Description:**

Product: Loose lay LVT  
Model: 7" x 48" x 4.5 mm  
Sample Quantity: 2 pieces  
Sample ID: S160107002SHF-001~002  
Date Received: 2016/1/7  
Date Test Conducted: 2016/1/7~2016/1/18

**Tests Conducted:**

As requested by the applicant, for details refer to attached pages(s).

**Conclusion:**

For details refer to attached page(s).  
The conclusions of this test report may not be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.

**Test Items, Method and Results:**

Test Item	Test Method	Test Result
Dimensional stability after exposure to heat	EN 434:1994	MD: 0.05% CMD: 0.10%
Curling after exposure to heat		0.08mm

**Appendix A: Sample received photo**



**Approved by:**

Name: Sun Sun  
Title: Approver

Name: Daniel Zhang  
Title: Reviewer

Name: Will Tan  
Title: Project Engineer

\*\*\*\*\*

The End of Report

*This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*